



# Campus Energy Audits - Big Data Analysis

Shane Esmore  
Umow Lai


**The Brief**

**The Sell**

**The Team**

**Audits & Reporting**

**Big Data Analysis**



## The Brief

- Conduct Level 2 Energy Audits (AS3598) for Approx 50 buildings (~200,000sqm)
- Develop Implementation Plan for Building Upgrades

# MACQUARIE UNIVERSITY CAMPUS MASTER PLAN 2014



## 50%

ENERGY  
REDUCTION  
on 2012 levels by 2030



Greenhouse Gases: 50% total reduction  
on 2012 levels (fossil fuel powered  
energy)



### EXISTING EMISSIONS


TOTAL GHG EMISSIONS: 45,707,239 kgCO<sub>2</sub>/yr

TOTAL GAS CONSUMED:  
75,285GJ/yr

TOTAL BUILDING FLOOR AREA:  
245,000 sqm

TOTAL ANNUAL ENERGY COSTS:  
\$6,856,000


TOTAL POWER CONSUMED:  
41.4GWh/yr



### POTENTIAL REDUCTIONS




HVAC



LIGHTING



EQUIPMENT



OTHERS


19% REDUCTION  
\$12.8M COST

28% REDUCTION  
\$4.7M COST

10% REDUCTION  
\$0.64M COST

21% REDUCTION  
\$1.2M COST

### Main Energy Users



- HVAC
- Lighting
- Equipment
- Others

EFFICIENCY IMPROVEMENT:  
17%

ROOFTOP SOLAR:  
FURTHER 1,704,522kgCO<sub>2</sub>/yr  
AVOIDED 9 YEAR PAYBACK

SAVINGS OVER 10 YEAR PERIOD:  
\$11,956,273

TOTAL GHG REDUCTIONS:  
7,731,397kgCO<sub>2</sub>/yr

TOTAL COST OF MEASURES:  
\$18,358,400



ENERGY SAVINGS INITIATIVES NOMINATED IN AUDIT PROJECT

## The Sell

- Detailed analysis of buildings metered data
- Site visits to all buildings
- Energy Audit report for all buildings
- Big Data analysis of results with overall site wide presentation

## The Team



Hugh Wilson  
Senior  
Associate




Richard Stokes  
Sustainability  
Consultant



Afroz Awan  
Mechanical  
Engineer



Mock  
Up






Mock  
Up

Filters


- Year
- (All)
  - 1
  - 2
- Type
- (All)
  - Delivery Centre (DC)
  - Delivery Facility (DF)
  - Gateway Facility (GF)
  - Hub
  - Letter Centre (LC)
  - Letter Facility (LF)
  - Mail Centre (MC)
  - Mail Sorting Centre (MSC)
  - Parcel Centre (PC)
  - Parcel Facility (PF)
  - Post Connect
  - Sorting Centre (SC)
- State
- (All)
  - ACT
  - New South Wales
  - Queensland
  - Victoria
- Location
- (All)
  - Alexandria
  - Albion Park
  - Baywater
  - Berrima
  - Bundaberg
  - Canberra
  - Central Coast
  - Central West NSW
  - Clayton South Mail
  - Clayton South MC
  - Clayton South PC
  - Cobar
  - Dandenong

MACQUARIE UNIVERSITY HVAC Audit Results

Umow Lai





Total 5 Year Cost per Project





# Legend

kWh/m<sup>2</sup> pa




conference venues  
car parking

INFORMATION AND SECURITY

- NOTES:
1. C1A - INFORMATION & SECURITY
  2. C8A - STUDENT ENQUIRY SERVICE
  3. ROOM LOCATION : Zone/Site/Block - Level/Room  
e.g. E 7 B - 2 63
  4. PARKING ONLY IN ESTABLISHED CARPARKS @  
● PAY & DISPLAY DISPENSING TICKET MACHINES

# MACQUARIE UNIVERSITY CAMPUS 2008







Between the birth of the world and 2003, there were five Exabyte of information created. We now create five Exabyte every two days

Eric Schmidt


Over **24 Petabytes** Data processed by Google\* every day in 2011










Data



































Umow Lai Your Project Name Energy Dashboard - Electricity

Inputs in Green Meter Use (Multiple Values)



Legend

Complete Dataset



- Power (kW)
- Power (kVA)


Time Filters

14/03/2013 12:00:00 AM 31/03/2013 11:59:59 PM

Year (All) Quarter (All) Month (All) Day (All) Weekday (All) Hour (All)

Power Factor

Box and Whiskers \*



Power Factor Distribution



Power Factor Stats

Max. Power Factor	1.00
Avg. Power Factor*	0.90
Load Factor*	0.244
Demand Factor #	0.286

\* Please note, these values are averaged where multiple meters are selected.

# The Demand Factor is calculated with reference to the Max. Demand input below.


Data Collection Frequency	4 data points / hour
Max. Demand	600 kW

Filtered Analysis Power


Power Statistics

Max. Power	172 kW
Min. Power	6 kW
Max. Power (kVA)	224 kVA
Min. Power (kVA)	8 kVA

Power Consumption Breakdown



Peak and Off Peak Power (kW) Distribution




- Peak
- Off-Peak

- Meter 1
- Meter 2
- Meter 3
- Meter 4
- Meter 5

Energy / Cost / Carbon

Cost Statistics



Peak Tariff	\$0.25 / kWh
Off-Peak	\$0.15 / kWh
Demand	\$6.00 / kW max

The above tariffs and charges are approximate only and do not include standing charges or account of line losses.

Carbon Statistics


Electricity Carbon Factor	1,350 kgCO2/kWh
Carbon Emissions	122 tCO2e
Black Balloons *	2,439,698

\* As per the Sustainability Victoria ad where 50g of carbon dioxide is visually represented by a black balloon.


Energy Statistics

Energy	90,359 kWh
% Peak Energy	49%
Peak Energy	44,594 kWh
% Off Peak Energy	51%
Off-Peak Energy	45,765 kWh
% On-Site Energy Generated On-Site	0.00%
On-Site Energy	0 kWh

Energy Breakdown



Peak and Off Peak Energy








Umow Lai

Your Project Name Energy Dashboard - Electricity



Legend

Inputs in Green Meter Use (Multiple values)




14/03/2013 12:00:00 AM 31/03/2013 11:59:59 PM

Year (All) Quarter (All) Month (All) Day (All) Weekday (All) Hour (All)


Box and Whiskers \*



Power Factor Profile \*



Power Factor Distribution



Power Factor Stats

Max. Power Factor	1.00
Avg. Power Factor*	0.90
Load Factor*	0.244
Demand Factor #	0.286

Data Collection Frequency: 4 data points / hour

Max. Demand: 600 kW


\* Please note, these values are averaged where multiple meters are selected.

# The Demand Factor is calculated with reference to the Max. Demand input below.


Power Statistics

Max. Power	172 kW
Min. Power	6 kW
Max. Power (kVA)	224 kVA
Min. Power (kVA)	8 kVA

Power Consumption Breakdown




Peak and Off Peak Power (kW) Distribution



- Peak
- Off-Peak
- Meter 1
- Meter 2
- Meter 3
- Meter 4
- Meter 5

Cost Statistics



Peak Tariff	\$0.25 / kWh
Off-Peak	\$0.15 / kWh
Demand	\$ 6.00/ kW max

The above tariffs and charges are approximate only and do not include standing charges or account of line losses.

Carbon Statistics


Electricity Carbon Factor	1,350 kgCO2/kWh
Carbon Emissions	122 tCO2e
Black Balloons ^	2,439,698

^ As per the Sustainability Victoria ad where 50g of carbon dioxide is visually represented by a black balloon.


Energy Statistics

Energy	90,359 kWh
% Peak Energy	49%
Peak Energy	44,594 kWh
% Off Peak Energy	51%
Off-Peak Energy	45,765 kWh
% On-Site Energy	0.00%
Generated On-Site	0 kWh

Energy Breakdown



Peak and Off Peak Energy



Complete Dataset

Time Filters


Power Factor

Filtered Analysis

Power


Energy / Cost / Carbon

## Detailed Analysis




Identify Opportunities

Detailed Analysis



**ACTION**



Identify Opportunities

## Sharing the Data



Building(s)




**1** Provide access to the building's energy data

**2** We process the data in house




**3** Then provide interactive energy dashboards



## Audits, Reporting & Big Data Analysis

- Data from all reports forms results database
- Tableau used to analyse 'Big Data' and present conclusions



## Audit Process

The audit is being conducted through a number of phases outlined below.

- Phase 1 – Project Initiation (Kickoff & Planning)
  - Attend workshop & provide Reverse brief in form of a project plan;
- Phase 2 – Energy Audits (Implementation)
  - Review available existing building information for all sites;
  - Determine total consumption over the past 24 months;
  - Conduct Level 2 & Level 3 site audits for nominated buildings
  - Prepare preliminary report for PCG review and comment
  - Attend workshop and finalise report and submit to PCG
- Phase 3 – Implementation Plan (Discuss Recommendations)
  - Prepare preliminary Implementation plan to assist with the execution of the works



# Upgrade Options



**BUILDING/ENERGY  
MANAGEMENT SYSTEM:**

- CONTROL STRATEGIES
- SENSING/MONITORING
- PLANT OPERATION
- LEARNING/OPTIMISATION
- SUB-METERING



**HVAC SYSTEM:**

- RENEWAL/UPGRADE
- EFFICIENT PLANT & SYSTEMS
- THERMAL ZONING
- SETPOINT ADJUSTMENT
- INTELLIGENT CONTROLS



**OCCUPANT BEHAVIOUR:**

- EDUCATION
- SIGNAGE
- INCENTIVE PROGRAMS
- INTUITIVE CONTROLS



**BUILDING ENVELOPE:**

- HIGH PERFORMANCE  
FAÇADE
- SHADING DEVICES
- INSULATION
- BUILDING ORIENTATION



**OTHER ENERGY USES:**

- LIFTS: SMART CONTROLS
- HOT WATER: EFFICIENT  
GENERATION & FIXTURES
- SPECIALTY EQUIPMENT:  
HOURS OF OPERATION &  
CONTROL




**ELECTRICAL EQUIPMENT:**

- EFFICIENT PRODUCTS
- OPERATING TIMES
- OCCUPANT BEHAVIOUR
- AUTOMATED CONTROL
- STANDBY POWER REDUCTION



**DISTRICT/SHARED SYSTEMS:**

- THERMAL STORAGE
- CO-GENERATION
- DISTRICT COOLING/HEATING
- POWER SHARING
- LOAD BALANCING



**LIGHTING:**

- EFFICIENT FITTINGS - LED
- LUX LEVELS & TASK BASED  
LIGHTING
- LIGHTING ZONING
- MOTION DETECTION
- DAYLIGHT SENSING

**ON-SITE GENERATION:**

- PV SOLAR
- WIND
- DIRECT USE THERMAL




## Metering Challenges

- Metering Coverage and Intensity Varied
- Newer Buildings Have Extensive Sub-Metering
- Older Buildings Typically Authority Meter Only
- Four Central CHW Plants Serving Multiple buildings
- Trigeneration Plant Serving Multiple buildings
- No Metering Trees in Place

### METERING TREE - AUTHORITY METER EDB002518

METER LOCATION: E3B





# Data Analysis


Meter Use E4A Calc

## Appendix A - Smart Meter Analysis

The following charts provide insights into the University of Macquarie's metered data for the above referenced building. The building report includes scores and specific commentary on these items which are included for reference only.


Energy	% Peak	Peak Energy	% Off Peak	Off-Peak Energy	% Occupied	In Occupied Hours	GHG Emissions	Approx. Electricity Cost
857,326 kWh	64%	552,567 kWh	36%	304,759 kWh	48%	412,828 kWh	849 tCO2e	\$ 120,521

### Overall Power Profile - Full Year



The power profile for the building is shown here on the basis of the building's metered data. Through analysis of this power profile, various insights into the building's performance can be gained.

### HVAC Startup - Summer - Typical Week




The heating, ventilation and air-conditioning systems can consume a large portion of a

## Scoring

Parameter	Analysis		
	Commentary	Value	Score
HVAC Startup:	Many systems operate 24/7	Ok	●
Base Load Changes:	Base power load typically approx. 50KW - no change by season or in holidays/weekends (around 40W/m2)	Poor	●
Overnight Load Spikes:	No significant load spiking overnight	Good	●
Holidays:	Notable reduction in consumption over christmas and public holidays	Poor	●
Summer Energy Consumption:	Consumption appears fairly consistent regardless of season	Ok	●
Winter Energy Consumption:	Consumption appears fairly consistent regardless of season	Ok	●
Shoulder Energy Consumption:	Consumption appears fairly consistent regardless of season	Ok	●
General Energy Profile:	Consistent daily profile, though only down a quite a high base level	Ok	●
Building Layout and Function:	This building generally appears to be utilised as per its originally intended function	Good	●
		None	●
		None	●

### 2.3 Summary of Metered Energy Data Analysis

Overall, on the basis of the metered data analysis the building is scored as -2 on the scale shown below.



This score forms a portion of the building's overall score.

# Scoring

## 5.2 Lighting

Lighting Power Density							
Actual Condition:	Generally 2x36W T8 utilised. Some areas highly lit.						
Actual Score:	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
	-3	-2	-1	0	1	2	3
Potential Score:	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
Recommended Upgrade:	Replace with efficient (T5 or LED) throughout						
Order of Capital Cost:	\$90,000	Estimated % Reduction to Peak Elec:	5%				

Lighting Controls							
Actual Condition:	Manual controls. Many areas left on while unoccupied						
Actual Score:	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
	-3	-2	-1	0	1	2	3
Potential Score:	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
Recommended Upgrade:	Include occupancy sensors and controls						
Order of Capital Cost:	\$12,000	Estimated % Reduction to Peak Elec:	0%				

## Reporting

- Excel based
- Automated calculations
- Printed to PDF reports
- Quantified all information
- Generated a database
- Fast and consistent





Macquarie University Energy Strategy Stage 2  
Building Audits

Umwol Lai

Macquarie University Energy Strategy Stage 2  
Building Audits

Umwol Lai

Executive Summary

Introduction

Umwol Lai have undertaken an energy audit and building survey of Building E5B. The work included a building inspection which was undertaken on the 11/12/2014 and a detailed review of the available energy data for the building for the period 01/10/2013 to 1/10/2014 in general accordance with the Australian Standard AS/NZS:3598:2006.

This report provides a detailed overview of the results for Building E5B and should be read in conjunction with the site wide analysis report and building survey methodology reports.

Overview

Building E5B was constructed in 1976 39 years ago and was last refurbished in 2004. The 1185sqm of useable floor areas is predominantly Wet Labs spaces across 2 floors. The building uses electricity for space heating and electricity for domestic hot water. The building includes lifts. These details were used to form the benchmark for Building E5B and estimate the building's energy breakdown as shown in the pie charts below.

Figure 1 - Electricity Consumption Breakdown




Figure 2 - Gas Consumption Breakdown



Overall Assessed Building Performance

Overall, Building E5B has been assessed on Umwol Lai's 7 point scale as -2 (where -3 is very poor and +3 is very good). With regards to total energy consumption the building used 540 MWh between 1/10/2013 and 1/10/2014, making it the 29th largest energy consumer on campus. In terms of specific energy consumption, the building is ranked 8th worst on campus with an energy intensity of 456 kWh/m<sup>2</sup>year.


Several measures were identified to improve the building's performance and it is anticipated that the building could improve to a 3 rating on the same 7 point scale. The measures have been ordered to allow those which are the most effective to be prioritised in future upgrade works on the following page.



Greenhouse Gas Emissions

The greenhouse gas emissions associated with the operation of Building E5B have been calculated. It is estimated that if all the measures identified are implemented a 30% reduction could be achieved through building upgrades. This could be increased to 34% if on-site generation was considered. However this would still fall short of the University 50% target.

Figure 3 - GHG Emission Savings



Ranked Building Upgrade Measures

The following table lists the building upgrade measures that have been identified for Building E5B ranked in order of their payback from shortest to longest. The measures with payback of less than 10 years have been highlighted and a separate total has been provided.

Building Category	Upgrade	Upgrade Category	Estimated Cost	Energy Savings	Annual Savings	Simple Payback*	
1	Equipment Controls An audit of the building and each piece of equipment may yield New gas fired, possibly including solar boost hot water system, depending	Building Use Capital Works	\$ 5,000	11,200	\$ 1,700	3 yrs	✓
2	Domestic Hot Water	Capital Works	\$ 8,000	7,800	\$ 1,700	5 yrs	✓
3	Lighting Controls Include occupancy sensors and controls	Controls	\$ 12,000	16,200	\$ 2,400	5 yrs	✓
4	Ventilation System Include CO2 sensing and outside air modulation	Controls	\$ 13,000	10,700	\$ 1,600	9 yrs	✓
5	On-site generation 20kWp PV array across available roof area	Capital Works	\$ 44,000	24,000	\$ 4,900	9 yrs	✓
6	Lighting Power Density Replace with efficient (T5 or LED) throughout	Capital Works	\$ 90,000	48,600	\$ 8,300	11 yrs	!
7	Other Elec. Use Sources of heat (servers, chillers) could be isolated either outside (best) or in	Capital Works	\$ 20,000	10,400	\$ 1,600	13 yrs	!
8	Building Fabric Ensure operable windows are fastened closed and seal windows to replace	FM Upgrades	\$ 5,000	1,800	\$ 300	19 yrs	!
9	Heating Controls Full controls upgrade as part of HVAC refurbishment	Capital Works	\$ 50,000	13,400	\$ 2,000	25 yrs	!
10	Cooling Controls Full controls upgrade as part of HVAC refurbishment	Capital Works	\$ 100,000	13,400	\$ 2,000	No payback	!
11	Heating Efficiency Full A/C refurbishment should be considered. Costs split across cooling	Capital Works	\$ 160,000	13,400	\$ 2,000	No payback	!
12	Cooling Efficiency Full A/C refurbishment should be considered. Costs split across cooling	Capital Works	\$ 350,000	13,400	\$ 3,900	No payback	!
13	-	-	-	-	-	-	-
14	-	-	-	-	-	-	-
<b>Total (All Measures)</b>			<b>\$ 857,000</b>	<b>184,300</b>	<b>\$ 32,400</b>	<b>27 yrs</b>	
<b>Total (Only Measures with Payback &lt;10 Years)</b>			<b>\$ 82,000</b>	<b>69,800</b>	<b>\$ 12,300</b>	<b>7 yrs</b>	

Note: Energy consumption figures are kWh/year. Gas consumption has been converted from GJ to kWh in order to compare energy on a common metric.



Umwol Lai

Building E5B

Macquarie University  
Sydney Campus Building Energy Audit



## Macquarie University Energy Strategy Stage 2 Building Audits

Umow Lai

### 1.0 Building Overview

The following section provides an overview of Building E5B including details sourced from the RLB condition surveys and a photo obtained from the University's 'lost on campus' webpages.

Building survey completed by: Umow Lai	Date of survey: 11/12/2014	<b>Benchmarks</b>
Total Usable Floor Area (UFA): 1,185 sqm	Faculty: Science	<b>Electric</b>
Available Roof Area: 400 sqm	Extended Hours: Yes	Intensive Equipment: Yes
Number of Floors: 2	Intensity: 191.7 kWh/m <sup>2</sup> /yr	Total: 227,195 kWh/yr
Building Completion Date: 1976	Peak Elec: 137 kW	<b>Gas</b>
Most Recent Refurbishment: 2004	Standalone or District System: E6 CHW Network	Primary Space Type: Wet Labs
% of UFA for Primary: 70%	Intensity: 0 MJ/m <sup>2</sup> /yr	Secondary Space Type: Office, Admin
Space Heating: Elec	Total: 0 MJ/year	Space Heating: Elec
Domestic Hot Water: Elec	<b>Energy Costs</b>	Includes Lifts: Yes
Includes Lifts: Yes	Energy: \$0.15/kWh \$13.0/GJ	Includes HVAC: Yes
Other items of note: Extensive Lab equipment, Fume Cupboards, District Cooling	Demand: \$10.5/kW -	

Figure 4 - Location of Building E5B on Macquarie University's Sydney Campus





Figure 5 - Photo of Building E5B



## Macquarie University Energy Strategy Stage 2 Building Audits

Umow Lai

### 2.0 Energy Meter Analysis

The energy meter data that was available for Building E5B has been analysed in detail using Umow Lai's energy dashboards. The following observations provide a valuable insight into the building's performance.

#### 2.1 Numerical Data Observations

The following observations represent the building's key performance metrics and can be compared to good practice.

Parameter	Overall		Intensity		Analysis	
	Value	Unit	Value	Unit	Value	Score
Total Elec. Consumption:	540,376 kWh/year		456 kWh/m <sup>2</sup> /yr		-138% vs target	●
Gas Consumption <sup>1</sup> :	- GJ/year		- MJ/m <sup>2</sup> /yr		0% vs target	●
Overall Peak Power:	152 kW		128 W/m <sup>2</sup>		6% over avg.	●
Typical Peak Power:	92 kW		61% of peak		100% over avg.	●
Overnight Elec. Consumption:	208,922 kWh		176 kWh/m <sup>2</sup> /yr		39% of total	●
Peak Power Overnight:	80 kW		68 W/m <sup>2</sup>		87% of typical	●
Weekday Elec. Consumption:	397,309 kWh/yr		79,482 kWh/yr		74% of total	●
Saturday Elec. Consumption:	71,949 kWh/yr		61 kWh/m <sup>2</sup> /yr		91% of weekday	●
Unoccupied Elec. Consumption:	356,258 kWh/yr		301 kWh/m <sup>2</sup> /yr		66% of total	●
Average Power Factor:	0.98		n/a		Good	●
Minimum Power Factor:	0.96		n/a		Good	●
R <sup>2</sup> Value for Temp. vs Energy:	1		n/a		Good	●

<sup>1</sup> Overnight hours between 8pm and 5am

<sup>2</sup> Gas consumption based on area weighted portion of total gas consumption for metered buildings adjusted for performance.


#### 2.2 Descriptive Data Observations

The following table includes the general observations made from analysing the building's electricity data. Examples of charts depicting the flagged observations have been included in Appendix A.

Parameter	Analysis	
	Commentary	Value Score
HVAC Startup:	Many systems operate 24/7	Ok ●
Base Load Changes:	Base power load typically approx. 50kW - no change by season or in holiday/weekends (around 40kW/2)	Poor ●
Overnight Load Spikes:	No significant load spiking overnight	Good ●
Holidays:	Notable reduction in consumption over christmas and public holidays	Poor ●
Summer Energy Consumption:	Consumption appears fairly consistent regardless of season	Ok ●
Winter Energy Consumption:	Consumption appears fairly consistent regardless of season	Ok ●
Shoulder Energy Consumption:	Consumption appears fairly consistent regardless of season	Ok ●
General Energy Profile:	Consistent daily profile, though only down a quite a high base level	Ok ●
Building Layout and Function:	The building generally appears to be utilized as per its originally intended function	Good ●
	None	●
	None	●

#### 2.3 Summary of Metered Energy Data Analysis

Overall, on the basis of the metered data analysis the building is scored as -2 on the scale shown below.



This score forms a portion of the building's overall score.



## Macquarie University Energy Strategy Stage 2 Building Audits

Umow Lai

### 3.0 Metering Review

The following tables summarise the building's electricity, gas and thermal (if applicable) metering capabilities.

#### 3.1 Electricity Meters


Observation	Analysis	Value	Score
Sub-metering:	Electricity is sub-metered within the building with multiple sub-meters	Good	●
Integrity:	Metering data of good quality meter so should be of an appropriate standard.	Good	●
Labelling:	The labelling on the electricity meter was adequate.	Ok	●
Linked to BMS:	The meter is linked to the BMS.	Ok	●

#### 3.3 Thermal Meters

Observation	Analysis	Value	Score
Sub-metering:	Connection to District chilled water, but no thermal metering	Poor	●
Integrity:	None	Poor	●
Labelling:	None	Poor	●
Linked to BMS:	None	Poor	●

#### 3.3 Summary of Metering Review

Overall, on the basis of the building's metering the building is scored as 0 on the scale shown below.



This score forms a portion of the building's overall score.

#### 3.4 Additional Comments on Occupant Behaviour

No particular concerns about the way this building is being used by the occupants



**Macquarie University Energy Strategy Stage 2 Building Audits**

Umow Lai

**Macquarie University Energy Strategy Stage 2 Building Audits**

Umow Lai

**Macquarie University Energy Strategy Stage 2 Building Audits**

Umow Lai

**4.0 Observations From Site Inspection**

Overview of key energy consuming systems:

**Mechanical Services:**

ESB includes an array of different split type A/C systems throughout the facility. Many rooms included significant levels of laboratory equipment including process chillers and other heat producing items. Sensitive equipment is included in many areas that require 24/7 conditioning. Some room set points were advised by users to be 18°C. Users advised that A/C zones extended across multiple offices, and that over-cooling was common. A/C Control is generally manual.

**Electrical Services:**

Generally lighting is achieved through the use of 2x36W T8 fluorescent fittings. Some areas appeared significantly over-lit – room 135 for example included 11 off 2x36W lights – totalling 792W for a 30m2 room (26.4W/m2). Lighting control is generally manually switched – with users noting that they switch off lights when they leave and back on when they return the next day.

**Notable Items from Site Inspection:**

Computer servers are located within an office which is included in a cluster of 4 offices on a single A/C zone – this means the conditioning runs 24/7 and often overcools the other areas to maintain these computers in an acceptable environment. One area includes 2 off wall mounted split systems, however, these units are not used as they drip condensate when they are turned on. The facade of ESB is similar to ESA – including some shading built into the facade structure and a fairly significant extent of low quality glazing.

**5.0 Building Survey Assessment**

The various components of Building ESB were surveyed and have been allocated scores as follows.

**5.1 Heating Ventilation and Air Conditioning (HVAC)**

Building Fabric	
Actual Condition:	Brick Construction & concrete construction , reasonable percentage of glazing or mediocre quality. Shading built into facade
Actual Score:	0 1 2 3
Potential Score:	0 1 2 3
Recommended Upgrade:	Ensure operable windows are fastened closed and seal windows to reduce leakage
Order of Capital Cost:	\$5,000 Estimated % Reduction to Peak Elec: 0%

Ventilation System	
Actual Condition:	Fixed outside air where relevant. Mechanical toilet exhaust
Actual Score:	0 1 2 3
Potential Score:	0 1 2 3
Recommended Upgrade:	Include CO2 sensing and outside air modulation
Order of Capital Cost:	\$13,000 Estimated % Reduction to Peak Elec: 0%

Cooling Efficiency	
Actual Condition:	Mix-match of A/C Systems - splits etc.
Actual Score:	0 1 2 3
Potential Score:	0 1 2 3
Recommended Upgrade:	Full A/C refurbishment should be considered. Costs split across cooling & Heating
Order of Capital Cost:	\$350,000 Estimated % Reduction to Peak Elec: 10%

Cooling Controls	
Actual Condition:	All manual controls. Many systems 24/7
Actual Score:	0 1 2 3
Potential Score:	0 1 2 3
Recommended Upgrade:	Full controls upgrade as part of HVAC refurbishment
Order of Capital Cost:	\$100,000 Estimated % Reduction to Peak Elec: 0%

Heating Efficiency	
Actual Condition:	Mix-match of A/C Systems - splits etc.
Actual Score:	0 1 2 3
Potential Score:	0 1 2 3
Recommended Upgrade:	Full A/C refurbishment should be considered. Costs split across cooling & Heating
Order of Capital Cost:	\$160,000 Estimated % Reduction to Peak Elec: 0%

Heating Controls	
Actual Condition:	All manual.
Actual Score:	0 1 2 3
Potential Score:	0 1 2 3
Recommended Upgrade:	Full controls upgrade as part of HVAC refurbishment
Order of Capital Cost:	\$50,000 Estimated % Reduction to Peak Elec: 0%

**5.2 Lighting**

Lighting Power Density	
Actual Condition:	Generally 2x36W T8 utilized. Some areas highly lit.
Actual Score:	0 1 2 3
Potential Score:	0 1 2 3
Recommended Upgrade:	Replace with efficient (T5 or LED) throughout
Order of Capital Cost:	\$90,000 Estimated % Reduction to Peak Elec: 5%

Lighting Controls	
Actual Condition:	Manual controls. Many areas left on while unoccupied
Actual Score:	0 1 2 3
Potential Score:	0 1 2 3
Recommended Upgrade:	Include occupancy sensors and controls
Order of Capital Cost:	\$12,000 Estimated % Reduction to Peak Elec: 0%

**5.3 Equipment**

Equipment Power Density	
Actual Condition:	High level of equipment installation in building - lab equipment
Actual Score:	0 1 2 3
Potential Score:	0 1 2 3
Recommended Upgrade:	Specialist equipment required for use of the building. No improvement considered worthwhile
Order of Capital Cost:	\$0 Estimated % Reduction to Peak Elec: 0%

Equipment Controls	
Actual Condition:	Many items running full time.
Actual Score:	0 1 2 3
Potential Score:	0 1 2 3
Recommended Upgrade:	An audit of the building and each piece of equipment may yield potential for reducing consumption
Order of Capital Cost:	\$5,000 Estimated % Reduction to Peak Elec: 0%



**Macquarie University Energy Strategy Stage 2 Building Audits**

Umow Lai

**5.0 Building Survey Assessment**

The various components of Building EIA were surveyed and have been allocated scores as follows.

**5.1 Heating Ventilation and Air Conditioning (HVAC)**

Building Fabric	
Actual Condition:	Brick Construction, minimal glazing on eastern and western facade. Glazing on North and South facade shaded by vegetation or shading devices. Single glaze panels. Louvers.
Actual Score:	0 0 0 0 0 0 0
Potential Score:	0 -1 -2 -1 0 1 2 3
Recommended Upgrade:	Louvers along the facade installed in conditioned rooms to be closed and sealed to prevent leakage.
Order of Capital Cost:	\$8,000 Estimated % Reduction to Peak Elec: 0%

Ventilation Systems	
Actual Condition:	The building facade is fitted with louvers to allow building to be switched to Natural Ventilation Mode however system has been deactivated due to compliance.
Actual Score:	0 0 0 0 0 0 0
Potential Score:	0 0 0 0 0 0 0
Recommended Upgrade:	Ventilation mode is recommended to be utilised in shoulder seasons. The BMCS to be programmed to allow for night purge mode every night to reduce load during the day. Include motion detectors in toilets to trigger exhaust fan operation, include run on timer.
Order of Capital Cost:	\$9,000 Estimated % Reduction to Peak Elec: 0%

Cooling Efficiency	
Actual Condition:	Chilled water plant and chilled water fan coil units.
Actual Score:	0 0 0 0 0 0 0
Potential Score:	0 0 0 0 0 0 0
Recommended Upgrade:	Lower supply air temperature to reduce fan consumption. Includes recommissioning of building, and review of officers for suitability.
Order of Capital Cost:	\$16,800 Estimated % Reduction to Peak Elec: 0%

Cooling Controls	
Actual Condition:	Extensive scheduling within BMCS. All units scheduled to remain on during weekdays, regardless of occupancy.
Actual Score:	0 0 0 0 0 0 0
Potential Score:	0 0 0 0 0 0 0
Recommended Upgrade:	Reconfigure Ventilation Mode within building to allow mode activation during shoulder seasons. Education of occupants to encourage use of this mode during this time.
Order of Capital Cost:	\$4,800 Estimated % Reduction to Peak Elec: 0%

Heating Efficiency	
Actual Condition:	Heat recovery type chiller used to provide heating so chiller is required to run to provide heating. Reverse Cycle Chiller also installed.
Actual Score:	0 0 0 0 0 0 0
Potential Score:	0 0 0 0 0 0 0
Recommended Upgrade:	No energy savings initiatives considered worthwhile. For recommendation on improving heating performance, refer to Recommendations section below.



**Macquarie University Energy Strategy Stage 2 Building Audits**

Umow Lai

**5.4 Other**


Domestic Hot Water	
Actual Condition:	Hot water unit is expected to be of significant age (no access available during inspection)
Actual Score:	0 0 0 0 0 0 0
Potential Score:	0 -1 -2 -1 0 1 2 3
Recommended Upgrade:	New gas fired, possibly including solar boost hot water system, depending on demand
Order of Capital Cost:	\$8,000 Estimated % Reduction to Peak Elec: 3%

Other Elec. Use	
Actual Condition:	Some areas running 24/7 to support small array of PC's. Process chiller installed within rooms.
Actual Score:	0 0 0 0 0 0 0
Potential Score:	0 -1 -2 -1 0 1 2 3
Recommended Upgrade:	Sources of heat (servers, chillers) could be isolated either outside (best) or in small internal areas, and provided with local cooling
Order of Capital Cost:	\$20,000 Estimated % Reduction to Peak Elec: 0%

Other Gas Use	
Actual Condition:	N/A
Actual Score:	0 0 0 0 0 0 0
Potential Score:	0 0 0 0 0 0 0
Recommended Upgrade:	N/A
Order of Capital Cost:	\$0 Estimated % Reduction to Peak Elec: -

**5.5 Summary of Building Survey Review**

For the building survey, the building has achieved a score of -3 as shown on the scale shown below.



This score forms a portion of the building's overall score.

Umow Lai

**Macquarie University Energy Strategy Stage 2 Building Audits**

Umow Lai

**7.3 Total Energy Consumption and Cost Breakdown**

The total energy consumption, electrical power demand and total running cost has been observed for Building EAA and the maximum potential performance has been estimated on the basis of all of the opportunities identified.

Energy Use	Actual		Maximum Potential		Savings
	kWh/year	Cost	kWh/year	Cost	
Electricity	853,000	334	\$170,000	666,000	\$141,000
Natural Gas	-	\$0	-	\$0	\$0
<b>Total</b>	<b>853,000</b>	<b>-</b>	<b>\$170,000</b>	<b>666,000</b>	<b>-\$141,000</b>

\* Gas consumption has been converted from GJ to kWh in order to compare energy on a common metric.

Figure 10 - Energy Consumption Breakdown





Figure 11 - Approximate Cost Breakdown



**7.4 Total Greenhouse Gas Emissions**

The total Greenhouse Gas Emissions (GHG) that can be attributed to the operation of Building EAA have been calculated in order to establish a baseline. It is understood that the University is targeting a 50% improvement upon a 2012 baseline by 2030. The potential GHG emissions from Building EAA shown has been estimated on the basis of all the identified measures being implemented except on-site generation which has been separated for clarity.

Greenhouse Gas Emissions	Actual		Maximum Potential		Savings	
	kgCO2e/year	kgCO2e/year	kgCO2e/year	kgCO2e/year	kgCO2e/year	%
Electricity	895,175	133	699,308	104	195,867	29
Natural Gas	-	0	-	0	0	0%
<b>Total</b>	<b>895,175</b>	<b>133</b>	<b>699,308</b>	<b>104</b>	<b>195,867</b>	<b>29</b>

Figure 12 - GHG Emission Breakdown





Figure 13 - Potential GHG Emission Savings



**7.5 Overall Building Score**

Overall, on the basis of the metered data analysis, the building metering and the building survey, the building is scored as 0.6 as shown on the scale below. The building has been assessed as having the maximum potential to achieve a score of 2 through the upgrade measures identified.



The following section provides analysis of the estimated energy savings by the upgrade measures identified to achieve this potential score.





## Macquarie University Energy Strategy Stage 2 Building Audits

Umow Lai

## Macquarie University Energy Strategy Stage 2 Building Audits

Umow Lai

## Macquarie University Energy Strategy Stage 2 Building Audits

Umow Lai

### 6.0 Energy Savings Identified

The table below summarises the previously identified building upgrade measures including estimated capital installed costs, estimated operational energy savings and the simple payback for these measures. Following discussions with the University, all measures with a payback of less than 10 years have been implemented as indicated by the tick and crosses.

Building Category	Upgrade	Upgrade Category	Estimated Cost	Energy Savings	Annual Savings	Simple Payback -
Building Fabric	Ensure operable windows are fastened closed and seal windows to reduce	FM Upgrades	\$5,000	1,800	\$300	~ 19 yrs
Ventilation System	Include CO2 sensing and outside air modulation	Controls	\$13,000	10,700	\$1,600	~ 9 yrs
Cooling Efficiency	Full A/C refurbishment should be considered. Costs split across cooling	Capital Works	\$350,000	13,400	\$3,900	No payback
Cooling Controls	Full controls upgrade as part of HVAC refurbishment	Capital Works	\$100,000	13,400	\$2,000	No payback
Heating Efficiency	Full A/C refurbishment should be considered. Costs split across cooling	Capital Works	\$160,000	13,400	\$2,000	No payback
Heating Controls	Full controls upgrade as part of HVAC refurbishment	Capital Works	\$50,000	13,400	\$2,000	~ 25 yrs
Lighting Power Density	Replace with efficient (T5 or LED) throughout.	Capital Works	\$90,000	48,600	\$8,300	~ 11 yrs
Lighting Controls	Include occupancy sensors and controls	Controls	\$12,000	16,200	\$2,400	~ 5 yrs
Equipment Power Density	Specialist equipment required for use of the building. No improvement	None	\$0	0	\$0	-
Equipment Controls	An audit of the building and each piece of equipment may yield	Building Use	\$5,000	11,200	\$1,700	~ 3 yrs
Domestic Hot Water	New gas fired, possibly including solar boost hot water system, depending	Capital Works	\$8,000	7,800	\$1,700	~ 5 yrs
Other Elec. Use	Sources of heat (servers, chillers) could be isolated either outside (best) or in	Capital Works	\$20,000	10,400	\$1,600	~ 13 yrs
Other Gas Use	N/A	None	\$0	0	\$0	-
On-site generation	20kWp PV array across available roof area	Capital Works	\$44,000	24,000	\$4,900	~ 9 yrs
Building Layout and Functionality			\$0	\$0	\$0	-
				\$0	\$0	-
				\$0	\$0	-
<b>Total</b>			<b>\$857,000</b>	<b>184,300</b>	<b>\$32,400</b>	<b>~ 27 yrs</b>

\* Payback is calculated by dividing the estimated cost by the annual savings to determine the approximate number of years that it would take for the cost to be paid off. This does not include consideration of inflation, discount rates, fuel price escalation, maintenance, renewal etc and further detailed study is recommended for measures to be considered.

### 7.0 Results

On the basis of the building's usage type and assessed performance the breakdown of electricity and gas consumption has been estimated as summarised by the following tabs and charts. Additionally the potential energy consumption has been estimated on the basis of all of the measures being implemented as well as Greenhouse Gas Emissions.

#### 7.1 Electrical Breakdown

Category	Actual				Maximum Potential			
	Typical*	Score	%	kWh/year	Score	%	kWh/year	
HVAC	25%	-2.4	25%	134,000	2.5	18%	68,000	
Lighting	25%	-2.0	24%	130,000	3.0	17%	65,000	
Equipment	40%	-3.0	42%	225,000	3.0	56%	214,000	
Domestic Hot Water	5%	-2.0	5%	26,000	1.0	5%	18,000	
Other Electrical Processes	5%	-2.0	5%	26,000	2.0	4%	16,000	
<b>Total Electrical</b>	<b>100%</b>	<b>-2.5</b>	<b>100%</b>	<b>540,000</b>	<b>2.8</b>	<b>100%</b>	<b>380,000</b>	

\* Typical breakdown from Council of Australian Governments (COAG) National Strategy on Energy Efficiency - Baseline Energy Consumption and Greenhouse Gas Emissions in Commercial Buildings in Australia. Part 1 - Report, November 2012

Figure 6 - Electricity Consumption Breakdown





Figure 7 - Potential Electricity Savings



#### 7.2 Natural Gas Energy Breakdown


Category	Actual				Maximum Potential			
	Typical*	Score	%	GJ/year	Score	%	GJ/year	
Space Heating	0%	0.0	0%	0	0.0	0%	0	
Domestic Hot Water	0%	0.0	0%	0	1.0	0%	0	
Kitchen	0%	0.0	0%	0	0.0	0%	0	
Other Natural Gas Use	0%	0.0	0%	0	0.0	0%	0	
<b>Total Natural Gas</b>	<b>0%</b>	<b>0.0</b>	<b>0%</b>	<b>0</b>	<b>0.0</b>	<b>0%</b>	<b>0</b>	

\* Typical breakdown from Council of Australian Governments (COAG) National Strategy on Energy Efficiency - Baseline Energy Consumption and Greenhouse Gas Emissions in Commercial Buildings in Australia. Part 1 - Report, November 2012

Figure 8 - Gas Consumption Breakdown



Figure 9 - Potential Gas Savings



### 7.3 Total Energy Consumption and Cost Breakdown

The total energy consumption, electrical power demand and total running cost has been observed for Building ESB and the maximum potential performance has been estimated on the basis of all of the opportunities identified.

Energy Use	Actual			Maximum Potential		
	kWh/year	kW Peak	Cost	kWh/year	kW Peak	Savings
Electricity	540,000	152	\$100,000	380,000	125	\$73,000
Natural Gas	-	-	\$0	-	-	\$0
<b>Total</b>	<b>540,000</b>	<b>-</b>	<b>\$100,000</b>	<b>380,000</b>	<b>-</b>	<b>\$73,000</b>

\* Gas consumption has been converted from GJ to kWh in order to compare energy on a common metric.

Figure 10 - Energy Consumption Breakdown





Figure 11 - Approximate Cost Breakdown



### 7.4 Total Greenhouse Gas Emissions

The total Greenhouse Gas Emissions (GHG) that can be attributed to the operation of Building ESB have been calculated in order to establish a baseline. It is understood that the University is targeting a 50% improvement upon a 2012 baseline by 2030. The potential GHG emissions from Building ESB shown has been estimated on the basis of all of the identified measures being implemented except on-site generation which has been separated for clarity.

Greenhouse Gas Emissions	Actual			Maximum Potential			Savings		
	tCO2e/yr	tCO2e/yr	tCO2e/yr	tCO2e/yr	tCO2e/yr	tCO2e/yr	tCO2e/yr	tCO2e/yr	
Electricity	567,395	479	399,022	337	168,373	142	30%	0%	
Natural Gas	0	0	0	0	0	0	0%	0%	
<b>Total</b>	<b>567,395</b>	<b>479</b>	<b>399,022</b>	<b>337</b>	<b>168,373</b>	<b>142</b>	<b>30%</b>	<b>0%</b>	

Figure 12 - GHG Emission Breakdown





Figure 13 - Potential GHG Emission Savings



### 7.5 Overall Building Score

Overall, on the basis of the metered data analysis, the building metering and the building survey, the building is scored as -2.1 as shown on the scale below. The building has been assessed as having the maximum potential to achieve a score of 3 through the upgrade measures identified.



The following section provides analysis of the estimated energy savings by the upgrade measures identified to achieve this potential score.

Macquarie University Energy Strategy Stage 2  
Building Audits

Umow Lai


8.0 Further Analysis

The following sections explore the building survey and energy audit results further, comparing the cost effectiveness of the building upgrade works identified, the range of savings and payback from implementing some or all of these measures and how the building compares to the rest of the University of Macquarie Campus.

8.1 Cost Benefit Analysis

The cost benefit analysis for the identified upgrade measures for Building ESB demonstrates that some measures are more effective than others. The top 3 (best payback) and the bottom 3 (worst payback) measures have been listed.


Figure 14 - Cost Benefit Analysis for Potential Upgrade Measures



8.2 Total Estimated Energy Savings

Following on from the previous chart, this analysis looks at the total energy savings that are estimated from the top 3 measures collectively (green), all measures except the bottom 3 (orange) and all measures (red).


Figure 15 - Total Estimated Available Energy Savings from Building ESB



8.3 Estimated Payback

On the basis of the same categories from the previous chart, the payback has been estimated. It is evident that the top 3 measures have the shortest payback.

Figure 16 - Net Present Value Showing Simple Payback



Macquarie University Energy Strategy Stage 2  
Building Audits

Umow Lai

8.4 Cumulative Impact Analysis

Considering the cumulative cost and savings enabled by implementing the measures in their ranked order we can show the diminishing returns from the least effective measures. The most cost effective measures should be prioritised.


Figure 17 - Cumulative Costs vs Cumulative Savings



8.5 Total Energy Consumption Compared to Rest of Campus

The total energy consumption of the building can be compared to others on campus in order to identify the major users of energy for prioritising upgrade works. Further detail will be provided in the site wide analysis report.


Figure 18 - Total Energy Consumption (540 MWh/year) Compared to Campus (Rank 29)



8.6 Energy Intensity Compared to Rest of Campus

The energy intensity considers the efficiency of the building and allows the least efficient spaces to be identified.

Figure 19 - Energy Intensity (456 kWh/sqm/year) Compared to Campus (Rank 8)



8.7 Limitations

The figures presented in this analysis are based on the building survey and metered data analysis completed by Umow Lai for the purpose of identifying the most cost effective energy saving measures that could be applied to this building. The energy breakdown is

Macquarie University Energy Strategy Stage 2  
Building Audits

Umow Lai

9.0 Conclusions

ESB is showing as the highest energy intensity building on campus of those audited to date. This is reflective of the high density of laboratory and specialist equipment, the ad-hoc nature of much of the air conditioning system, and the fact that the building is essentially running as a 24/7 operation. Although there is metering information for the building, there is no other BMS data to analyse, or to provide the ability to review and control operations.

Several measures have been identified to improve the performance of the building, some of which have a payback of less than 10 years as per the University preference.

Included in these is a full HVAC refurbishment, which is a high cost exercise, but would offer the chance to reconcile all the mechanical systems, pressure, air delivery etc. to vary improve both the efficiency and comfort in the building. We anticipate that this would occur at the next major refurbishment, though if none is planned, it might be worthy of consideration regardless.

The anticipated savings from all of the measures identified are not sufficient for the building to achieve the Universities 50% reduction in Greenhouse Gas Emission baseline. Therefore it is recommended that:

- All measures with a payback of less than 10 years are considered in detail.
- Measures with a payback of 10 years or more are considered at the next major refurbishment for the building.
- The remaining Greenhouse Gas emission reductions required to achieve the University 50% reduction target are considered on a site-wide basis.

Please refer to the site wide report for further information on overall strategy.




# Implementation Plan



# Mapped Data Analysis

This dashboard plots the data gathered across the campus map to provide an overview of various results. The presented data can be changed using the highlighted inputs and filters in order to find information of interest.



# Overall GHG Intensity




Chart Data

GHG Emissions

Absolute (Total) or Intensity (per sqm)

Intensity




Overall Categories

- (All)
- Custom
- Equipment
- HVAC
- Lighting
- On-site generation
- Other

Upgrade Categories

- (All)
- 0
- Building Fabric
- Building Layout and Functionality
- Cooling Controls
- Cooling Efficiency
- Domestic Hot Water
- Equipment Density
- Equipment Power Density
- Heating Controls
- Heating Efficiency
- Lighting Controls
- Lighting Power Density
- On-site generation
- Other Elec. Use
- Other Gas Use
- Ventilation System



# HVAC Emissions Intensity





Chart Data


GHG Emissions

Absolute (Total) or Intensity (per sqm)

Intensity



- Overall Categories
- (All)
  - Custom
  - Equipment
  - HVAC
  - Lighting
  - On-site generation
  - Other
- Upgrade Categories
- (All)
  - Building Fabric
  - Cooling Controls
  - Cooling Efficiency
  - Heating Controls
  - Heating Efficiency
  - Ventilation System





# Greenhouse Gas Intensity Analysis


The greenhouse gas intensity (kgCO<sub>2</sub> per sqm per year) for each building has been ascertained from the smart meter data.

This can be compared to the estimated potential GHG emissions which has been calculated on the basis of the energy audit work undertaken.

The buildings have been grouped with those which have similar primary space types and those with and without HVAC in order to ascertain which are above and below average.

Key

- GHG Intensity
- Potential GHG Intensity





# Greenhouse Gas Intensity Analysis


This can be compared to the estimated potential GHG emissions which has been calculated on the basis of the energy audit work undertaken.

The building's have been grouped with those which have similar primary space types and those with and without HVAC in order to ascertain which are above and below average.


Key

- GHG Emissions - Intensity
- GHG Emissions - Potential - Intensity


Space Primary Space Type: / Includes HVAC: / Building



# Big Bad Buildings



# Cumulative Cost of Initiatives




# Cumulative Cost Savings Analysis

This chart features in the individual building reports, but is also very interesting for considering the campus as a whole. By ordering the building upgrades with those with the shortest payback to the left, we can see how far a certain amount of capital expenditure would go and when the returns become diminished (when the trend is flat).

The total annual cost savings are multiplied by a variable in order to show the total cost savings after so many years.

The size of the circle represents the extent of GHG emission savings available.




# Building Age vs Performance

This chart considers the relationship between building age and building performance.

The circle size represents the area of the building and the red circles indicate those which are entirely without HVAC due to their connection to the district energy system.

The data can be changed between GHG emissions, electricity and gas consumption.




# Payback Analysis

The simple payback is defined as the number of years that it takes for the capital expenditure to be offset by the estimated annual cost savings for each identified measure.

This chart plots the simple payback for each measure against the estimated cost of implementing each upgrade.

Through toggling the payback target a line can be drawn across those measures which may be worth considering.

Highlighting desirable measures returns a total upgrade cost at the foot of the screen.



# Upgrade Cost vs Payback Analysis

The simple payback is defined as the number of years that it takes for the capital expenditure to be offset by the estimated annual cost savings for each identified measure.

This chart plots the simple payback for each measure against the estimated cost of implementing each upgrade.

Through toggling the payback target a line can be drawn across those measures which may be worth considering.

Highlighting desirable measures returns a total upgrade cost at the foot of the screen.



# Payback Analysis – HVAC Controls

This chart plots the simple payback for each measure against the estimated cost of implementing each upgrade.

Through toggling the payback target a line can be drawn across those measures which may be worth considering.

Highlighting desirable measures returns a total upgrade cost at the foot of the screen.

Payback Target

5 years


■ HVAC

Overall Category

- (All)
- Custom
- Equipment
- HVAC
- Lighting
- On-site generation
- Other

Building Category

- (All)
- Building Fabric
- Cooling Controls
- Cooling Efficiency
- Domestic Hot Water
- Equipment Power Den...
- Heating Controls
- Heating Efficiency
- Lighting Controls
- Lighting Power Density
- On-site generation
- Other Elec. Use
- Ventilation System





# Payback Analysis – HVAC Controls


This chart plots the simple payback for each measure against the estimated cost of implementing each upgrade.  
Through toggling the payback target a line can be drawn across those measures which may be worth considering.  
Highlighting desirable measures returns a total upgrade cost at the foot of the screen.

Payback Target HVAC

5 years

Overall Category

- (All)
- Custom
- Equipment
- HVAC
- Lighting
- On-site generation
- Other



# Payback Analysis – DHW

This chart plots the simple payback for each measure against the estimated cost of implementing each upgrade.  
Through toggling the payback target a line can be drawn across those measures which may be worth considering.  
Highlighting desirable measures returns a total upgrade cost at the foot of the screen.

Payback Target

5 years


Other

Overall Category

- (All)
- Custom
- Equipment
- HVAC
- Lighting
- On-site generation
- Other

Building Category

- (All)
- Building Fabric
- Cooling Controls
- Cooling Efficiency
- Domestic Hot Water
- Equipment Controls
- Equipment Power Den...
- Heating Controls
- Heating Efficiency
- Lighting Controls
- Lighting Power Density
- On-site generation
- Other Elec. Use
- Ventilation System



# Payback Analysis – Lighting Density

This chart plots the simple payback for each measure against the estimated cost of implementing each upgrade.  
Through toggling the payback target a line can be drawn across those measures which may be worth considering.  
Highlighting desirable measures returns a total upgrade cost at the foot of the screen.

Payback Target

5 years

0

< >


■ Lighting

Overall Category

- (All)
- Custom
- Equipment
- HVAC
- Lighting
- On-site generation
- Other

Building Category

- (All)
- Building Fabric
- Cooling Controls
- Cooling Efficiency
- Domestic Hot Water
- Equipment Controls
- Equipment Power Den...
- Heating Controls
- Heating Efficiency
- Lighting Controls
- Lighting Power Density
- On-site generation
- Other Elec. Use
- Ventilation System



# Payback Analysis – Lighting Controls

This chart plots the simple payback for each measure against the estimated cost of implementing each upgrade.

Through toggling the payback target a line can be drawn across those measures which may be worth considering.

Highlighting desirable measures returns a total upgrade cost at the foot of the screen.

Payback Target

5 years


■ Lighting

Overall Category


- (All)
- Custom
- Equipment
- HVAC
- Lighting
- On-site generation
- Other

Building Category


- (All)
- Building Fabric
- Cooling Controls
- Cooling Efficiency
- Domestic Hot Water
- Equipment Controls
- Equipment Power Den...
- Heating Controls
- Heating Efficiency
- Lighting Controls
- Lighting Power Density
- On-site generation
- Other Elec. Use
- Ventilation System



**5.9 EXAMPLE INITIATIVE – LIGHTING POWER DENSITY**



**Upgrade Cost vs Payback**



**Figure 13 Lighting Controls Cost Vs Payback**

# Building Score Card

Overview of Building E08


Benchmark Assumptions

Building	Faculty	Floors	Space Primary Space Type:	Secondary Space Type:	Completed	Most Recent Refurb	Total UFA (sqm)	Includes Lifts:	Includes HVAC:	Space Heating:	Domestic Hot Water:	Other items of note:	Electrical Benchmark (kWh/yr)	Gas Benchmark (GJ/yr)	Peak Electrical Demand Benchmark (kW)
E8B	Science	3	Office, Admin	Dry Labs, Speciality Learning, Libraries	1972	1998	1,216	No	Yes	Gas	Gas	Partially air conditioned - ad hoc arrangement. Museum on Ground	145,594	222	122


Potential\*




GHG Emissions Split\*




Overall Score Actual and Potential



GHG Saving Potential\*



Building E8B Location




Building E8B Upgrade List

Building Category	Upgrade Detail	Elec Savings (kWh/yr)	Gas Savings (GJ/yr)	Total Cost Savings	Upgrade Cost	Simple Payback	GHG Savings (kgCO2/yr)
On-site generation	10kWp PV array across available roof area	15,000	0	\$2,912	\$22,000	7.6	15,750
Lighting Controls	Full lighting controls upgrade - automated scheduling, motion and light level detection	8,961	0	\$1,344	\$13,750	10.2	9,409
Lighting Power Density	Upgrade all lighting to high efficient T5 fittings (or LED)	26,881	0	\$4,309	\$54,000	12.5	28,225
Cooling Controls	Removal of portable A/C, incorporating schedules for chilled beams. Note - assumes A/C full refurb. Costs combined with heating controls	2,028	0	\$304	\$5,000	16.4	2,130
Ventilation System	Occupancy sensor for Toilet exhaust	1,082	20	\$361	\$6,000	16.6	2,410



# Overall GHG By Faculty






# Overall GHG Emissions Review

Looking at the whole campus combined (for the building's included to date) the potential GHG reductions from all of the energy saving measures identified is not sufficient to achieve the University 50% reduction target by 2030.

These figures currently do not include PV and are subject to change.

Maximum GHG Emission Potential vs Targets







MACQUARIE  
University



Umow Lai

# Macquarie University Energy Strategy


Audit Results & Implementation Plan - Executive  
Briefing



## Other Big Data Applications

- NABERS Energy Tracking
- PV and cogen feasibility
- Existing building performance analysis
- HVAC Condition Audits
- Analysing and presenting modelling results
- Mapping our projects on the website

### ACU Thermal Comfort Analysis



The thermal comfort modelling results for the proposed stair at the Australian Catholic University (ACU) building on Victoria Parade are shown below.

The results have been filtered for occupied hours (8am to 5pm) in the summer months of January to March only for a typical year (hourly weather data from 2002).

The inputs marked in blue can be toggled to further filter the results.

#### Key

- Outdoor Dry Bulb
- PMV
- Zone Mean Air Temp
- Zone Mean Radiant Temp

Level Assessed

Ground

Level 5

Glass Type

(All)

EC Glass

SHGC 0.35

SHGC 0.55

Peak Operative Temp.

28°C

#### Predicted Mean Vote (PMV)

	SHGC 0.55	SHGC 0.35	EC Glass
% of PMV in Excellent Range (+/- 0.5)	50%	58%	51%
% of PMV in Good Range (+/- 1)	75%	77%	73%
% of PMV in Ok Range (+/- 2)	91%	96%	94%
Average PMV	0.5	-0.2	-0.5

#### Air Temperature

	SHGC 0.55	SHGC 0.35	EC Glass
% of Time within 1 °C of Control Band (21-24°C)	70%	79%	81%
Hours above Peak Operative Temp.	119 hrs	56 hrs	31 hrs
% of Time Above Peak Operative Temp.	19%	9%	5%
Average Internal Air Temperature	25.6°C	24.4°C	23.9°C

#### Radiant Temperature

	SHGC 0.55	SHGC 0.35	EC Glass
% of Time within Target (20-27°C)	17%	42%	62%
Hours Above Temperature Target (27°C)	531 hrs	363 hrs	228 hrs
% of Occupied Time Above Target (27°C)	83%	57%	36%
Average Radiant Temperature	30.2 °C	27.2 °C	25.9 °C



DETAILED

ACCURATE

OVERVIEW





Umow Lai

Deviation % 95%  105%

150 Collins Street NABERS Energy Tracking

Benchmark - Modelled Data

Reporting

ACCURATE

Total % Deviation: 99%

Total Volume Deviation: -2,995

Deviation % League Table

Deviation Volume League Table

Meter	Area	Meter Description	Meter Equipment	Deviation %	Rank (By %)
VM-BHG-03	Base Building	Boilers (Gas)	Boiler 1, Boiler 2	104%	14
VM-BMP-07	Base Building	Boilers (Elec.)	Boiler 1, Boiler 2	100%	13
VM-BMP-03	Base Building	AHU Fans	Supply and Return Air Fans	100%	12
VM-BHG-02	Base Building	Cogenerator (Gas)	Cogeneration Gas Engine	99%	11
VM-BMP-04	Base Building	Packaged A/C Units	BOH Water Cooled Units, BOH Split Units	99%	10
VM-BMP-08	Base Building	Cogenerator	HHW Reclaim and CCW Pumps	99%	9
VM-TMP-01	Tenant	Tenant Condenser Water (Elec.)	Tenant CCW	99%	8
VM-BHG-01	Base Building	Domestic Hot Water	Domestic Hot Water Boiler	99%	7
VM-BMP-06	Base Building	Other Fans	Exhaust, Ventilation, Carpark, Smoke Spill	99%	6
VM-BEL-01	Base Building	Lighting	Common Area, Toilets, Carpark, Back of House and Pla.	98%	5
VM-BVP-01	Base Building	Lifts	All Lifts	98%	4
VM-BMP-02	Base Building	HVAC Pumps	HHW Pumps, CHW Pumps	98%	3
VM-BMP-05	Base Building	Heat Rejection	Base Building and Cogen Cooling Towers, CCW	98%	2
VM-BMP-01	Base Building	Chillers (Elec.)	Chiller 1, Chiller 2, Chiller 3	98%	1

Meter	Area	Meter Description	Meter Equipment	Volume Deviation	Rank (By Volume)
VM-BHG-03	Base Building	Boilers (Gas)	Boiler 1, Boiler 2	37.9	14
VM-BMP-07	Base Building	Boilers (Elec.)	Boiler 1, Boiler 2	0.6	13
VM-BMP-03	Base Building	Domestic Hot Water	Domestic Hot Water Boiler	-5.8	12
VM-BMP-08	Base Building	Cogenerator	HHW Reclaim and CCW Pumps	-21.2	11
VM-BMP-04	Base Building	AHU Fans	Supply and Return Air Fans	-43.6	10
VM-TMP-01	Tenant	Tenant Condenser W.	Tenant CCW	-45.4	9
VM-BMP-04	Base Building	Packaged A/C Units	BOH Water Cooled Units, BOH Split Units	-87.3	8
VM-BMP-06	Base Building	Other Fans	Exhaust, Ventilation, Carpark, Smoke Spill	-178.2	7
VM-BVP-01	Base Building	Lifts	All Lifts	-194.6	6
VM-BHG-02	Base Building	Cogenerator (Gas)	Cogeneration Gas Engine	-288.0	5
VM-BMP-05	Base Building	Heat Rejection	Base Building and Cogen Cooling Towers, CCW	-290.2	4
VM-BEL-01	Base Building	Lighting	Common Area, Toilets, Carpark, Back of House and Plan.	-397.9	3
VM-BMP-02	Base Building	HVAC Pumps	HHW Pumps, CHW Pumps	-552.3	2
VM-BMP-01	Base Building	Chillers (Elec.)	Chiller 1, Chiller 2, Chiller 3	-920.1	1

FILTERS  
Applies to all charts and tables


Evaluate (Chart Y Axis)  
GHG Emissions (kgCO2e)

Area  
(All)

Meter (Description)  
(All)

100% Occupancy Date From  
1/20/2015

Periodic Tracking of Actual Data Compared to Modelled Benchmark





The charts to the left represent the actual data and the as-designed modelled performance for benchmarking purposes. Monthly data is considered broadly suitable for comparisons but it should be noted that actual weather patterns (e.g. a very hot month) may not align with the modelled weather which may skew results.

The charts below reflect daily and hourly comparisons in energy use compared to the modelled benchmark. Please note that the modelled data at this level of detail is less likely to be suitable for direct comparisons so is provided for reference only.

Additional Detailed Analysis

Reference Only



FILTERS  
For daily and hourly charts only

Select Year  
2014

Select Month  
January

Select Day  
2

OVERVIEW

Umow Lai


150 Collins Street Base Building NABERS Tracking Overview

Target NABERS Star Rating:


Evaluate:

NABERS Elec Data Source:

NABERS Energy Rating - Monthly Tracking



Monthly Performance vs NABERS Benchmark Allowance




Umow Lai

150 Collins Street Base Building NABERS Tracking Overview

OVERVIEW


NABERS Status Tracking per Month

NABERS Elec Data Source  
Base Building Elec Main Supply



Deviation per Meter

ACCURATE







Umow Lai

150 Collins Street Cooling and AHU Fans

DETAILED

Months in Year: 2014

Days in Month: December

kgCO2e



Deviation .. 95% 105%



Umow Lai

150 Collins Street Cooling and AHU Fans


Evaluate

GHG Emissions (kgCO2e)

Months in Year: 2014



Days in Month: December

Hours in Day: 27



AHU Fans

DETAILED



Deviation .. 85% 105%

Umow Lai




Project Name Energy Dashboard - Electricity



Legend

- Power (kW)
- Power (kVA)



Inputs in Blue	Meter Use (All)	Energy	% Peak Energy	Peak Energy	% Off Peak Energy	Off-Peak Energy	% On-Site Energy	Generated On-Site	GHG Emissions
		4,247,566 kWh	55%	2,337,430 kWh	45%	1,910,136 kWh	0.00%	0 kWh	5,734 tCO2e



Time Filters

31/12/2012 12:00:00 AM to 14/01/2013 11:59:59 PM

Year (All) Quarter (All) Month (All) Day (All) Weekday (All) Hour (All)





Power Factor Stats

Max. Power Factor	1.00
Avg. Power Factor*	0.93
Load Factor*	0.094
Demand Factor #	0.863

Max. Demand: 600 kW


\* Please note, these values are averaged where multiple meters are selected.  
# The Demand Factor is calculated with reference to the Max. Demand input below.



Power Statistics

Max. Power	518 kW
Min. Power	1 kW
Max. Power (kVA)	601 kVA
Min. Power (kVA)	1 kVA

- Peak
- Off-Peak
- BB Meter 1
- Meter 1
- Meter 2
- Meter 3
- Meter 4
- Meter 5
- Meter 6
- Meter 7
- Meter 8
- Meter 9





Greenhouse Gas Emissions

Peak Tariff	\$0.08 / kWh
Off-Peak	\$0.09 / kWh
Demand	\$ 6.66/ kW max

The above tariffs and charges are approximate only and do not include standing charges or account of line lo..

Greenhouse Gas Emissions

Electricity GHG Emission Factor	1.350 kgCO2/kWh
GHG Emissions	237 tCO2e



Energy Summary

Energy	175,706 kWh
% Peak Energy	56%
Peak Energy	98,573 kWh
% Off Peak Energy	44%
Off-Peak Energy	77,133 kWh
% On-Site Energy	0.00%
Generated On-Site	0 kWh

Complete Dataset

Time Filters

Power Factor

Filtered Analysis Power

Energy / Cost / GHG Emissions

Umow Lai


Project Name Energy Dashboard - Electricity

Inputs in Blue	Meter Use (All)	Logo
Energy	% Peak Energy	Peak Energy
4,247,566 kWh	55%	2,337,430 kWh
		% Off Peak Energy
		45%
		Off-Peak Energy
		1,910,136 kWh
		% On-Site Energy
		0.00%
		Generated On-Site
		0 kWh
		GHG Emissions
		5,734 tCO2e

Power Profile (kW and kVA)



Power (kW) Distribution





Power Factor Distribution



Legend

- Power (kW)
- Power (kVA)

HVAC Startup - Summer - Typical Week





Peak Tariff	\$0.08 / kWh
Off-Peak	\$0.09 / kWh
Demand	\$ 6.66/ kW max

The above tariffs and charges are approximate only and do not include standing charges or account of line to.

Greenhouse Gas Emissions

Electricity GHG Emission Factor	1,350 kgCO2/kWh
GHG Emissions	237 tCO2e




Energy Summary

Energy	175,706 kWh
% Peak Energy	56%
Peak Energy	98,573 kWh
% Off Peak Energy	44%
Off-Peak Energy	77,133 kWh
% On-Site Energy	0.00%
Generated On-Site	0 kWh

- Meter 1
- Meter 2
- Meter 3
- Meter 4
- Meter 5
- Meter 6
- Meter 7
- Meter 8
- Meter 9

Complete Dataset  
Time Filters  
Filtered Analysis  
Energy / Cost / GHG Emissions





Filters

MAPS

Australia Post - Nationwide HVAC Audit Results

Key Stats





### Academic Building

Total Gas Cost: **\$3,486.48**


Natural Gas :**387,387.0 MJ**

Natural Gas Cost: **\$3,486.48**

Liquid LPG: **0 litres**

LPG Cost: **\$0.00**

Duration of Use: **710.3 hours**





Questions?